

**ADDENDUM No. 2
to
BID DOCUMENTS
for
Cuyahoga Community College
East Campus Food Service - Einstein Bagel Site Prep
4250 Richmond Road
Highland Hills, OH 44122**

June 19, 2019

-
- A. The original bidding documents for the above referenced project are hereby amended as noted in Addendum No.2.
 - B. This Addendum supersedes and takes precedence over information provided prior to the date of this Addendum.
 - C. Attachments to this Addendum includes: None

RFIs and Responses

- 1. What type of vapor barrier is used referenced in Detail A1 on Dwg. A-103?
GPD Response: Contractor to verify that the insulation is unfaced prior to installing a new vapor barrier. If the insulation is unfaced the basis of design shall be CertainTeed MemBrain.
- 2. A2 Hanger Detail on Dwg. M-501 on who you mean by "Provided by Others" for SS Threaded Rod and Washers and Nuts?
GPD Response: Delete "provided by others" Contractor to provide all items in A2 Hangar Detail.
- 3. Detail A1 on Dwg. A-101: There are no front elevations showing the height of ceramic tile walls. There are also two conflicting notes about "new" gyp and "gyp to remain."?
GPD Response: The Ceiling Height is listed on Sheet A102 Detail A3. Finish schedule is listed on A103. Regarding gypsum demolition; The intention for demolition is to remove only what is necessary for installation of new work. Please also review the details for appropriate backing for all new finishes.

SPECIFICATION REVISIONS:

- 1. None

DRAWING REVISIONS:

- 1. None

END OF ADDENDUM No. 2